

**DELAWARE HEALTH
AND SOCIAL SERVICES**

DIVISION OF PUBLIC HEALTH

OFFICE OF DRINKING WATER

PHONE: (302) 739-5410

FAX: (302) 739-8388

OFFICE OF DRINKING WATER

Blue Hen Corporate Center

Suite 203

655 Bay Road

Dover, Delaware 19901

FAX NUMBER: (302) 739-8388

TELECOPY TRANSMITTAL FORM

PLEASE DELIVER TO:

Amy Cohen

AT:

USEPA

FAX NUMBER:

215-814-2302

FROM:

Ed Hall

DATE:

4/3/03

NUMBER OF PAGES (Including Transmittal Form)

2

Please acknowledge receipt of this fax at Telephone Number: (302) 739-5410

If there are any problems with transmission, please call: Ed Hall at (302) 739-5410

ORIGINAL WILL BE MAILED:

☐ YES☒ NO

REMARKS:

Here it is. Call if you have questions
EdH



**DELAWARE HEALTH
AND SOCIAL SERVICES**

DIVISION OF PUBLIC HEALTH

OFFICE OF DRINKING WATER

PHONE: (302) 739 - 5410

FAX: (302) 739 - 8388

March 28, 2003

Jeffrey Smith, REM
Environmental Manager
Mountaire Farms of Delaware, Inc.
P.O. Box 1320
Millsboro, Delaware 19966

RE: Alternate Drinking Water Options

Dear Mr. Smith.

Thank you for the information on the nitrate removal systems. The Division of Public Health Office of Drinking Water accepts Underwriter's Laboratories, Inc. certification for compliance with ANSI/NSF 61 standards. Therefore, the Ecowater 1000 S/S with A-520E nitrate select resin system and the Ecowater ESS 2000R30 with nitrate select resin that you submitted are acceptable for use in complying with the EPA order.

If you have any questions, please feel free to contact me at 302-739-5410, or by email at Edward.Hallock@state.de.us, or at the address noted below.

Sincerely,

A handwritten signature in black ink, appearing to read "E. Hallock".

Edward G. Hallock
Program Administrator
Office of Drinking Water

File ✓